AOV Systems Ltd, Unit G10 Woodroyd Mills Cleckheaton BD19 3AF



Tel: 01422 825940

## **Roof Open Sky-Warranty**

## Ventilation Products

For ful details please refer to Powrmatic's Term and Condition of Sale, these can be found on the Powrmatic website, www.powrmatic.co.uk

## Guarantee/Warranty,

Powrmatic Ltd's ventilators and controls (where provided) are fully guaranteed for 12 months from date of delivery. Powrmatic Ltd ventilators are designed to provide robust and effective operation in reasonable environmental conditions. Powrmatic ventilators can include consumable items such as actuators and batteries, the life span of which are subject to operation cycles and environmental factors such as temperature as detailed in our Operation and Maintenance information. Consumable items are guaranteed for 12 months. Please note whilst our guarantee covers parts and labour, we are not responsible for providing any access equipment necessary to rectify a fault, or change a component. Our guarantee is based on the following conditions;

- The ventilator/s must have been installed in accordance with our fixing details or drawings.
- The ventilator/s must have been professionally commissioned.
- The ventilator/s have been used for the purpose for which they are designed, and internal building pressures must be calculated to ensure the pressures are not greater than the mechanical resistance of the product.
- No unauthorized repairs or modifications have been made to the ventilator/s.

Powrmatic Ltd will not be liable in respect of any claim for direct or indirect consequential losses, including loss of profits or increased costs arising from loss of use of the ventilator/s (or controls), or any event arising there from.

In the event of there being a requirement to provide a warranty for Powrmatic Ltd ventilators, we can confirm that we would be willing to provide such a warranty subject to agreement on wording. In some cases a warranty may be subject to an additional charge.

To ensure the correct and full operation of the ventilation system, it must be maintained in accordance with the product Operation and Maintenance Manual.